

Government of Tripura
Directorate of Fire & Emergency Services
Tripura, Agartala.

Phone: 0381-2326451. Fax: 0381-2324826. Email: dfireservicetripura@gmail.com. Website: www.fireservice.tripura.gov.in

No.3-8/TF&ES/2021/ 1928-30

Dated, Agartala, the 15th February, 2021.


To
The Director,
Delhi World Public School,
Gurkhabasti, Agartala.
Email-principal@dwpsagartala.in
Ph. No. 7640838858.

Subject: - Issuance of Fire NOC.

With reference to your compliance report under letter No. Nil dated 30.01.2021, it is hereby certified that the building /premises as per description below has been inspected by the officer concerned of this Department on 05.02.2021. In respect of implementation of Fire Safety measures, it was found that said building have complied with the Fire Prevention and Fire Safety requirements in accordance with provisions of the Part-4 of the latest National Building Code, 2016. The premises/building is issued NOC with effect from 15.02.2021 for a period of 01 (one) year subject to compliance of the conditions for the validity of Fire NOC.

Name & address of the proposed building / premises: - Delhi World Public School, VIP Road, Gurkhabasti, Agartala.

Issued on 15.02.2021 at Agartala.


Joint Director,
Tripura Fire & Emergency Services.

Conditions for the Validity of Fire NOC.

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all times. Any lapse in this regard shall make the owner /management liable for action.
2. There should not be any change of Trade for which this License has been issued.
3. Building sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the Fire Safety Certificate stands null and void.
4. Water reservoir should always be kept full up to the brim.
5. The entrance and exit and the water reservoir should always be free from any obstructions.
6. The staff shall be trained for operating fire fighting system and mock evacuation drills be Conducted at regular intervals and record be maintained.

Copy to :-

1. The Divisional Fire Officer, West Division, Agartala for information.
2. OC, Agartala Fire Station for favour of Information.



Vincent Verma
Jayeshkanti Majumdar